



HIMACHAL PRADESH PUBLIC WORKS DEPARTMENT


School Building safety Certificate.

The School building of D.A.V Centenary Public School situated at Nangal road Una Tehsil & Distt.Una, inspected by the concerned Junior Engineer. It has been observed that no earth quake resistance provision has been adopted for this building and no structure drawing is approved by the competent Govt. certified Engineer which has been produced at the time of inspection and moreover no assistance was taken from Public Works Department for construction of the building. Hence the structural safety of this building cannot be assured specifically from earthquake resistance point of view. This department will not be held responsible for any type of loss of life and property etc. If this structure falls under any circumstances.However as per the visual inspection it has been observed that the existing building seems to be safe for running acadmic session **2023-24**, as per guidelines issued by the Special Secretary (PW) to the Govt. of H.P notification No. PBW (B) E (3)95/2019 dated 13.4.2021. No Officer/ official of this department would attend any plea in any Hon'ble Court of law for any type of dispute and claim and loss.

This certificate is only for official use and not for legal purpose.


Assistant Engineer
Una Sub Division No-I
HP,PWD Una


Executive Engineer
Una Division (B&R)
H P P W.D. Una (H.P.)


(ATTESTED)
Principal
D.A.V. Centenary Public School
Nangal Road Una (H.P.)-174305