

OFFICE OF THE CHIEF EXECUTIVE OFFICER  
JANPAN PANCHAYAT (Block), KESHKAL,  
DISTRICT - KONDAGAON (C.G.)

FIRE SAFETY  
CERTIFICATE


Ref No - . 3760

Date: 26/05/2023

Certified that the D,A,V Mukhyamantri Public School, (started as Government Model School prior to 2016 by the Education Department of the Government of Chhattisgarh) , constructed by PWD Kondagaon on government land, located at village Garka, Post: Singanpur, Dist- Kondagaon ,comprised of one ground floor and one upper floor basements owned/ occupied by D.A.V. Mukhyamantri Public school, Garka, have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the undersigned 23/05/2023 in the presence of Mrutyunjay Panigrahi, Principal, and that the building/ premises is fit for occupancy up to classes up to XII, with effect from the issue date to a period of 04 years .in accordance with rule and subject to compliance of specific conditions as appended.

1. Installation of Fire Extinguishers from registered supplier.
2. Refilling of extinguishers containers and the expiry date must be mentioned.
3. Proper evacuation exit point and provision of safe assembly area. .
4. Basement area is free from mass kitchen or storing of inflammable articles

Issued on: /05/2023

  
Signature  
(L.K. Kawre)  
Chief Executive Officer,  
Janpad Pannhayat, Keshkal

---

To  
The Principal/Manager, D.A.V Mukhyamantr Public School,  
Garka, Post: Singanpur, Dist – Kondagaon, (C.G.)

Copy Corresponded to: District Education Officer, Kondagaon, (C.G.)